

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.7			Y
2	7.6			Y
3	7.6			Y
4	7.7			Y
5	7.4			Y
6	7.3	53.7	1.19	Y
7	7.6			Y
8	7.8			Y
9	7.7			Y
10	7.7			Y
11	7.7	59.4	1.40	Y
12	7.7			Y
13	7.7			Y
14	7.7			Y
15	7.7			Y
16	7.7			Y
17	7.8			Y
18	7.7	59.9	1.25	Y
19	7.7			Y
20	7.8			Y
21	7.7			Y
22	7.8			Y
23	7.7			Y
24	7.7			Y
25	7.7	59.2	1.28	Y
26	7.7			Y
27	7.7			Y
28	7.6			Y
29	7.6			Y
30	7.6			Y
(No = N = Excursion) 0				
TOTAL N'S				

<<Have minimums been met for this day?

County: Clatsop Agency: CLATSOP COUNTY

**ENTRY POINT**  
**EP-A**

**PWS ID 4190416**

**Georgia-Pacific CLCP Wauna**

**Sample Period: September 2023** \_\_\_\_\_  
Month/Year

Number of excursions\* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 7.2  
 PO4 0.5 (Orthophosphate)

Print Name: Terry Force

Signature:

Date: 10-3-2023

Phone: 503-455-3331

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>