



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.6			Y
2	7.6	58.4	1.07	Y
3	7.6			Y
4	7.7			Y
5	7.7			Y
6	7.5			Y
7	7.7			Y
8	7.7			Y
9	7.7	60.2	1.12	Y
10	7.7			Y
11	7.5			Y
12	7.6			Y
13	7.7			Y
14	7.6			Y
15	7.6			Y
16	7.6	60.8	1.30	Y
17	7.6			Y
18	7.6			Y
19	7.6			Y
20	7.6			Y
21	7.5			Y
22	7.6			Y
23	7.6	59.1	1.2	Y
24	7.6			Y
25	7.7			Y
26	7.7			Y
27	7.7			Y
28	7.7			Y
29	7.7			Y
30	7.7			Y
31	7.7			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this day?

County: Clatsop Agency: CLATSOP COUNTY

ENTRY POINT
EP-A

PWS ID 4190416
Georgia-Pacific CLCP Wauna
Sample Period: October 2023
Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

 PO4

0.5

 (Orthophosphate)

Print Name: Terry Force
 Signature:
 Date: 11-3-2023
 Phone: 503-455-3331

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>