



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.7			Y
2	7.7			Y
3	7.7			Y
4	7.7			Y
5	7.6			Y
6	7.7	61.4	1.36	Y
7	7.7			Y
8	7.7			Y
9	7.7			Y
10	7.6			Y
11	7.6			Y
12	7.4			Y
13	7.5	53.1	1.16	Y
14	7.6			Y
15	7.6			Y
16	7.6			Y
17	7.6			Y
18	7.7			Y
19	7.7			Y
20	7.6	61.9	1.27	Y
21	7.6			Y
22	7.6			Y
23	7.6			Y
24	7.7			Y
25	7.6			Y
26	7.6			Y
27	7.6	63.2	1.20	Y
28	7.6			Y
29	7.6			Y
30	7.7			Y
(No = N = Excursion)				0
<b>TOTAL N'S</b>				

<<Have minimums been met for this day?

County: Clatsop      Agency: CLATSOP COUNTY

**ENTRY POINT**  
**EP-A**

**PWS ID 41-90416**

**Georgia-Pacific CLCP Wauna**

**Sample Period: November 2023**  
*Month/Year*

**Number of excursions\* during this month: 0** (Count the number of days when any WQP was less than the minimum required)


**Total excursions during the previous 5 months: 0** (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH	<b>7.2</b>	
PO4	<b>0.5</b>	(Orthophosphate)

**Print Name:** Darrel Lockard Cert#2853

**Signature:** 

**Date:** 12/6/2023

**Phone:** 541-505-9968

**Send to DWP within 10 days after end of sampling period**

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>