



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.8			Y
2	7.6			Y
3	7.6			Y
4	7.7	65.8	1.10	Y
5	7.6			Y
6	7.7			Y
7	7.7			Y
8	7.7			Y
9	7.4			Y
10	7.4			Y
11	7.4	38.5	1.32	Y
12	7.8	41.0	1.32	Y
13	7.5			Y
14	7.5			Y
15	7.5			Y
16	7.6			Y
17	7.7			Y
18	7.4	49.8	1.51	Y
19	7.4			Y
20	7.5			Y
21	7.5			Y
22	7.5			Y
23	7.5			Y
24	7.7			Y
25	7.8			Y
26	7.7			Y
27	7.7			Y
28	7.7			Y
29	7.6			Y
30	7.7			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this day?

County: Clatsop Agency: CLATSOP COUNTY

ENTRY POINT
EP-A

PWS ID 41-90416
Georgia-Pacific CLCP Wauna
Sample Period: December 2023
Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

PO4

0.5

 (Orthophosphate)

Print Name: Darrel Lockard Cert# 2853

Signature: Darrel Lockard
Digitally signed by Darrel Lockard
DN: cn=Darrel Lockard, o=Delta Operations, ou,
email=bmcm5@aol.com, c=US
Date: 2024.01.05 09:22:15 -0800

Date: 1/5/2023

Phone: 541-505-9968

Send to DWP within 10 days after end of sampling period
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>