



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.8			Y
2	7.8			Y
3	7.7	67.0	1.43	Y
4	7.7			Y
5	7.8			Y
6	7.7			Y
7	7.5			Y
8	7.5	58.5	1.34	Y
9	7.8			Y
10	7.8			Y
11	7.8			Y
12	7.8			Y
13	7.7			Y
14	7.5			Y
15	7.5			Y
16	7.5			Y
17	7.8			Y
18	7.6			Y
19	7.8	48.1	1.29	Y
20	7.7			Y
21	7.7			Y
22	7.5	41.5	1.31	Y
23	7.4			Y
24	7.4			Y
25	7.5			Y
26	7.5			Y
27	7.5			Y
28	7.5			Y
29	7.6			Y
30	7.5			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this day?

County: Clatsop Agency: CLATSOP COUNTY

ENTRY POINT
EP-A

PWS ID 41-90416
Georgia-Pacific CLCP Wauna

Sample Period: January 2024
Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 PO4 0.5 (Orthophosphate)

Print Name: Darrel Lockard Cert# 2853

Signature: Darrel Lockard Digitally signed by Darrel Lockard
DN: cn=Darrel Lockard, o=Delta Operations,
ou, email=bmcm5@aol.com, c=US
Date: 2024.02.05 10:21:49 -0800

Date: 2 / 5 / 2024

Phone: 541-505-9968

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>