



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.4			Y
2	7.5			Y
3	7.6			Y
4	7.6			Y
5	7.6	50.5	1.44	Y
6	7.6			Y
7	7.7			Y
8	7.7			Y
9	7.6			Y
10	7.7			Y
11	7.9			Y
12	7.8	56.8	1.33	Y
13	7.7			Y
14	7.8			Y
15	7.8			Y
16	7.8			Y
17	7.8			Y
18	7.8			Y
19	7.7			Y
20	7.5			Y
21	7.5			Y
22	7.6			Y
23	7.6	61.6	1.39	Y
24	7.5			Y
25	7.5			Y
26	7.7			Y
27	7.7			Y
28	7.6			Y
29	7.6			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this day? County: Clatsop Agency: CLATSOP COUNTY

**ENTRY POINT
EP-A**

PWS ID 41-90416

Georgia-Pacific CLCP Wauna

Sample Period: February 2024
Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 PO4 0.5 (Orthophosphate)

Print Name: Darrel Lockard Cert# 2853

Signature: 

Date: 3/4/2024

Phone: 541-505-9968

Send to DWP within 10 days after end of sampling period