



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Y/N
1	7.55			Y
2	7.75			Y
3	7.54			Y
4	7.53	52.2	1.40	Y
5	7.69			Y
6	7.67			Y
7	7.54			Y
8	7.49			Y
9	7.80			Y
10	7.73			Y
11	7.71	62.9	1.30	Y
12	7.54			Y
13	7.83			Y
14	7.90			Y
15	7.47			Y
16	7.28			Y
17	7.51			Y
18	7.49	57.0	1.01	Y
19	7.56			Y
20	7.45			Y
21	7.68			Y
22	7.61			Y
23	7.60			Y
24	7.70			Y
25	7.72	64.4	0.94	Y
26	7.65			Y
27	7.57			Y
28	7.50			Y
29	7.72			Y
30	7.75			Y
31	7.42			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this day? County: Clatsop Agency: CLATSOP COUNTY

**ENTRY POINT**  
**EP-A**

**PWS ID 41-90416**  
**Georgia-Pacific CLCP Wauna**

**Sample Period: March 2024**  
*Month/Year*

**Number of excursions\* during this month: 0** (Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months: 0** (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 7.2  
 PO4 0.5 (Orthophosphate)

Print Name: Darrel Lockard Cert# 2853

Signature: Darrel Lockard Digitally signed by Darrel Lockard  
DN: cn=Darrel Lockard, o=Delta Operations,  
ou, email=brmcms2@aol.com, c=US  
Date: 2024.04.04 09:13:15 -07'00'

Date: 4/3/2024

Phone: 541-505-9968

**Send to DWP within 10 days after end of sampling period**

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>