



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.53	62.0	1.04	Y
2	7.74			Y
3	7.89			Y
4	7.67			Y
5	7.75			Y
6	7.84			Y
7	7.74			Y
8	7.66	66.4	1.19	Y
9	7.64			Y
10	7.68			Y
11	7.55			Y
12	7.63			Y
13	7.62			Y
14	7.71			Y
15	7.73	67.1	1.21	Y
16	7.48			Y
17	7.58			Y
18	7.79			Y
19	7.76			Y
20	7.71			Y
21	7.41			Y
22	7.82	73.3	1.11	Y
23	7.82			Y
24	7.56			Y
25	7.50			Y
26	7.40			Y
27	7.69			Y
28	7.60			Y
29	7.44			Y
30	7.67			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this day? County: Clatsop Agency: CLATSOP COUNTY

**ENTRY POINT
EP-A**

PWS ID 41-90416

Georgia-Pacific CLCP Wauna

Sample Period: April 2024

Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 PO4 0.5 (Orthophosphate)

Print Name: Darrel Lockard Cert# 2853

Signature: Darrel Lockard Digitally signed by Darrel Lockard
 DN: cn=Darrel Lockard, o=Delta Operations, ou,
 email=bmcm5@aol.com, c=US
 Date: 2024.05.06 09:42:14 -07'00'

Date: 5/6/2024

Phone: 541-505-9968

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>