



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.75			Y
2	7.78			Y
3	7.39	60.6	1.10	Y
4	7.71			Y
5	7.71			Y
6	7.72			Y
7	7.65			Y
8	7.56			Y
9	7.60			Y
10	7.61	54.2	1.13	Y
11	7.61			Y
12	7.43			Y
13	7.66			Y
14	7.66			Y
15	7.49			Y
16	7.50			Y
17	7.74	56.7	1.12	Y
18	7.78			Y
19	7.51			Y
20	7.47			Y
21	7.68			Y
22	7.75			Y
23	7.69			Y
24	7.47			Y
25	7.70			Y
26	7.71			Y
27	7.56			Y
28	7.63			Y
29	7.66			Y
30	7.57			Y
(No = N = Excursion) TOTAL N'S				0

<<Have minimums been met for this day? County: Clatsop Agency: CLATSOP COUNTY

ENTRY POINT
EP-A

PWS ID 41-90416
Georgia-Pacific CLCP Wauna
Sample Period: June 2024
Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH **7.2**

PO4 **0.5** (Orthophosphate)

Print Name: Darrel Lockard Cert# 2853

Signature: Darrel Lockard Digitally signed by Darrel Lockard
DN: cn=Darrel Lockard, o=CLATSOP COUNTY, email=brnclm@clatsop.com, c=US
Date: 2024.07.01 15:22:54 -0700

Date: 7/1/2024

Phone: 541-505-9968

Send to DWP within 10 days after end of sampling period
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>