



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.41	54.4	1.18	Y
2	7.44			Y
3	7.68			Y
4	7.69			Y
5	7.49			Y
6	7.44			Y
7	7.50			Y
8	7.47	56.2	1.24	Y
9	7.45			Y
10	7.47			Y
11	7.63			Y
12	7.67			Y
13	7.42			Y
14	7.45			Y
15	7.31	57.2	1.09	Y
16	7.49			Y
17	7.50			Y
18	7.46			Y
19	7.59			Y
20	7.63			Y
21	7.61			Y
22	7.68	58.6	1.10	Y
23	7.68			Y
24	7.72			Y
25	7.48			Y
26	7.54			Y
27	7.69			Y
28	7.69			Y
29	7.69			Y
30	7.60			Y
31	7.61			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this day?

County: Clatsop Agency: CLATSOP COUNTY

ENTRY POINT
EP-A

PWS ID 41-90416
Georgia-Pacific CLCP Wauna
Sample Period: July 2024
Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH
PO4 (Orthophosphate)

7.2
0.5

Print Name: Darrel Lockard Cert# 2853

Signature: *Darrel Lockard*

Date: 8/8/24

Phone: 541-505-9968

Send to DWP within 10 days after end of sampling period
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>