

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.7			Y
2	7.5			Y
3	7.6			Y
4	7.6			Y
5	7.6			Y
6	7.7			Y
7	7.8	60.4	1.20	Y
8	7.7			Y
9	7.6			Y
10	7.6			Y
11	7.6			Y
12	7.7			Y
13	7.7			Y
14	7.6	61.0	1.02	Y
15	7.5			Y
16	7.7			Y
17	7.6			Y
18	7.6			Y
19	7.6			Y
20	7.6			Y
21	7.6	60.4	1.08	Y
22	7.6			Y
23	7.6			Y
24	7.6			Y
25	7.6			Y
26	7.6			Y
27	7.6			Y
28	7.7			Y
29	7.6			Y
30	7.7			Y
31	7.6			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this day?

County: Clatsop Agency: CLATSOP COUNTY

**ENTRY POINT
EP-A**

PWS ID 4190416

Georgia-Pacific CLCP Wauna

Sample Period: October / 2024
Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

PO4 (Orthophosphate)

7.2
0.5

Print Name: Darrel Lockard Cert# 2853

Signature: Darrel Lockard
Digitally signed by Darrel Lockard
DN: cn=Darrel Lockard, o=Delta Operations, ou,
email=bmcm5@aol.com, c=US
Date: 2024.11.06 12:22:20 -08'00'

Date: 11/06/2024

Phone: 541-505-9968

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>