

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.6			Y
2	7.6			Y
3	7.6			Y
4	7.6	60.3	1.16	Y
5	7.6			Y
6	7.6			Y
7	7.6			Y
8	7.5			Y
9	7.6			Y
10	7.4			Y
11	7.5	61.7	1.27	Y
12	7.5	61.8	1.10	Y
13	7.6			Y
14	7.5			Y
15	7.6			Y
16	7.5			Y
17	7.6			Y
18	7.6	55.4	1.20	Y
19	7.5			Y
20	7.6			Y
21	7.6			Y
22	7.6			Y
23	7.6			Y
24	7.5			Y
25	7.5	49.1	1.10	Y
26	7.3			Y
27	7.5			Y
28	7.5			Y
29	7.7			Y
30	7.7			Y
31				
(No = N = Excursion)0				
TOTAL N'S				

<<Have County: Clatsop Agency: CLATSOP COUNTY

minimums
been met for
this day?

**ENTRY POINT
EP-A**

PWS ID 4190416

Georgia-Pacific CLCP Wauna

Sample Period: November / 2024

Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH	7.2	(Orthophosphate)
PO4	0.5	

Print Name: Darrel Lockard Cert# 2853

Signature: _____

Date: 12/06/2024

Phone: 541-505-9968

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>