



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.65			Y
2	7.69	55.5	1.26	Y
3	7.74			Y
4	7.68			Y
5	7.72			Y
6	7.77			Y
7	7.80			Y
8	7.79			Y
9	7.73	65.7	1.19	Y
10	7.76			Y
11	7.76			Y
12	7.71			Y
13	7.66			Y
14	7.71			Y
15	7.52			Y
16	7.64	67.5	1.23	Y
17	7.71			Y
18	7.68			Y
19	7.68			Y
20	7.38			Y
21	7.37			Y
22	7.61			Y
23	7.64	53.2	1.21	Y
24	7.61			Y
25	7.59			Y
26	7.64			Y
27	7.61			Y
28	7.56			Y
29	7.49			Y
30	7.50			Y
31	7.59			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this day? County: Clatsop Agency: CLATSOP COUNTY

ENTRY POINT
EP-A

PWS ID 4190416
Georgia-Pacific CLCP Wauna
Sample Period: December / 2024
Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 PO4 0.5 (Orthophosphate)

Print Name: Darrel Lockard Cert# 2853

Signature: Darrel Lockard Digitally signed by Darrel Lockard
DN: cn=Darrel Lockard, o=Delta Operations,
ou, email=bmcm5@aol.com, c=US
Date: 2025.01.07 14:45:25 -0800

Date: 1/7/2025

Phone: 541-505-9968

Send to DWP within 10 days after end of sampling period
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>