



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.7			Y
2	7.6			Y
3	7.6			Y
4	7.6			Y
5	7.6			Y
6	7.6	49.4	1.27	Y
7	7.9			Y
8	7.6			Y
9	7.5			Y
10	7.8			Y
11	7.7			Y
12	7.7			Y
13	7.7	54.0	1.42	Y
14	7.7			Y
15	7.9			Y
16	7.8			Y
17	7.6			Y
18	7.6			Y
19	7.7			Y
20	7.7			Y
21	7.8			Y
22	7.8			Y
23	7.7			Y
24	7.8	61.7	1.29	Y
25	7.5			Y
26	7.5			Y
27	7.6	64.5	1.29	Y
28	7.7			Y
29	7.8			Y
30	7.8			Y
31	7.8			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have

County: Clatsop

Agency: CLATSOP COUNTY

minimums
been met for
this day?

ENTRY POINT

EP-A

PWS ID 41-90416

Georgia-Pacific CLCP Wauna

Sample Period: January 2025

Month/Year

Number of excursions* during this month: 0 *(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0 *(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH

7.2

PO4

0.5

(Orthophosphate)

Print Name:

Darrel Lockard Cert# 2853

Signature:

Darrel Lockard

Digitally signed by Darrel Lockard
DN: cn=Darrel Lockard, o=Delta Operations, ou,
email=dlm@delta.com, c=US
Date: 2025.02.05 11:25:04 -0800

Date:

2/5/2025

Phone:

541-505-9968

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-
0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>