



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.7				Y
2	7.7				Y
3	7.7	73.1	1.52		Y
4	7.8				Y
5	7.8				Y
6	7.8				Y
7	8.0				Y
8	8.0				Y
9	7.7				Y
10	7.7	68.2	1.41		Y
11	7.7				Y
12	7.8				Y
13	7.8				Y
14	7.8				Y
15	7.8				Y
16	7.8				Y
17	7.7				Y
18	7.8				Y
19	7.7				Y
20	7.6				Y
21	7.6	62.3	1.78		Y
22	7.6				Y
23	7.6				Y
24	7.6	54.3	1.66		Y
25	7.7				Y
26	7.5				Y
27	7.3				Y
28	7.5				Y
29					
30					
31					

(No = N = Excursion) Total N's

<<Have  
minimums  
been met for  
this day?

ENTRY POINT

PWS ID: 41

9 0 4 1 6

System Name: Georgia-Pacific, Wauna Mill

Entry Point: First User

Sample Period: February 2025

Month/Year

Number of excursions\* during this month: 0

(Count the number of days when any WQP was  
less than the minimum required)

Total excursions during the previous 5 months: 0

(Over 9 excursions in 6 months is a violation. Entry  
Point and Distribution excursions are cumulative )

For OHA use only

Minimum Water Quality  
Parameters as set by

pH 7.2

Alk (Alkalinity)

PO4 0.5 (Orthophosphate)

Other ( )

Print Name: Darrel Lockard Cert#2853

Signature: Darrel Lockard

Date: 3/6/2025

Send to DWP within 10 days after end of  
sampling period