



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.7			Y
2	7.8			Y
3	7.7			Y
4	7.8			Y
5	7.8	60.1	1.52	Y
6	7.7			Y
7	7.8			Y
8	7.9			Y
9	7.8			Y
10	7.7	65.5	1.8	Y
11	7.7			Y
12	7.7			Y
13	7.6			Y
14	7.4			Y
15	7.6			Y
16	7.7			Y
17	7.6	72.7	7.2	Y
18	7.5			Y
19	7.6			Y
20	7.5			Y
21	7.7			Y
22	7.5			Y
23	7.5			Y
24	7.5	57.5	1.43	Y
25	7.6			Y
26	7.5			Y
27	7.6			Y
28	7.6			Y
29	7.6			Y
30	7.7			Y
31	7.7			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this day?

County: Clatsop Agency: CLATSOP COUNTY

ENTRY POINT

EP-A

PWS ID 4190416

Georgia-Pacific CLCP Wauna

Sample Period: March / 2025

Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
PO4 0.5 (Orthophosphate)

Print Name: Darrel Lockard Cert# 2853

Signature: Darrel Lockard
Digitally signed by Darrel Lockard
DN: cn=Darrel Lockard, ou=Delta Operations,
ou_email=lrlockard@psd.com, c=US
Date: 2025.04.04 11:46:51 -0700

Date: 4/4/2025

Phone: 541-505-9968

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>