

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.7			Y
2	7.7			Y
3	7.7			Y
4	7.6			Y
5	7.6			Y
6	7.9			Y
7	7.6	62.4	1.43	Y
8	7.6			Y
9	7.7			Y
10	7.7			Y
11	7.7			Y
12	7.6			Y
13	7.7			Y
14	7.7	60.0	1.47	Y
15	7.6			Y
16	7.6			Y
17	7.7			Y
18	7.7			Y
19	7.7			Y
20	7.7			Y
21	7.6	56.7	1.45	Y
22	7.7			Y
23	7.7			Y
24	7.5			Y
25	7.6			Y
26	7.6			Y
27	7.6			Y
28	7.7	61.5	1.38	Y
29	7.5			Y
30	7.5			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have

County: Clatsop

Agency: CLATSOP COUNTY

minimums
been met for
this day?

ENTRY POINT

EP-A

PWS ID 4190416

Georgia-Pacific CLCP Wauna

Sample Period: April / 2025

Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH

PO4

(Orthophosphate)

7.2

0.5

Print Name:

Darrel Lockard Cert# 2853

Signature:

Darrel Lockard

Digitally signed by Darrel Lockard
DN: cn=Darrel Lockard, o=Clatsop County, ou=Clatsop County, email=Darrel.Lockard@clatsopcounty.org, c=US

Date:

5/6/2025

Phone:

541-505-9968

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 873-0405 Website: <http://healthoregon.org/dwp/>