

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.5			Y
2	7.6			Y
3	7.7			Y
4	7.7			Y
5	7.7	61.5	1.43	Y
6	7.7			Y
7	7.6			Y
8	7.7			Y
9	7.6			Y
10	7.6			Y
11	7.7			Y
12	7.7	59.7	1.35	Y
13	OFF			Y
14	OFF			Y
15	OFF			Y
16	OFF			Y
17	7.6			Y
18	7.6			Y
19	7.6	44.7	1.48	Y
20	7.7			Y
21	7.7			Y
22	7.6			Y
23	7.7			Y
24	7.8			Y
25	7.6			Y
26	7.5			Y
27	7.6			Y
28	7.5	51.1	1.86	Y
29	7.6			Y
30	7.8			Y
31	7.8			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have
minimums
been met for
this day?

County: Clatsop

Agency: CLATSOP COUNTY

ENTRY POINT

EP-A

PWS ID 4190416

Georgia-Pacific CLCP Wauna

Sample Period: May / 2025

Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

7.2

PO4

0.5

(Orthophosphate)

Print Name: **Darrel Lockard Cert# 2853**

Signature:

Darrel Lockard

Date:

6/9/25

Phone:

541-505-9968

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>