

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.7			Y
2	7.7	49.8	1.27	Y
3	7.7			Y
4	7.7			Y
5	7.7			Y
6	7.6			Y
7	7.6			Y
8	7.6			Y
9	7.5	49.7	1.62	Y
10	7.5	50.4	1.59	Y
11	7.5			Y
12	7.6			Y
13	7.6			Y
14	7.5			Y
15	7.6			Y
16	7.6	51.9	1.50	Y
17	7.6			Y
18	7.6			Y
19	7.6			Y
20	7.6			Y
21	7.6			Y
22	7.4			Y
23	7.5	51.4	1.54	Y
24	7.5			Y
25	7.6			Y
26	7.6			Y
27	7.5			Y
28	7.5			Y
29	7.6			Y
30	7.4			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have

County: Clatsop

Agency: CLATSOP COUNTY

minimums
been met for
this day?

ENTRY POINT

EP-A

PWS ID 41-90416

Georgia-Pacific CLCP Wauna

Sample Period: June 2025

Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH

7.2

PO4

0.5

(Orthophosphate)

Print Name:

DARREL LOCKARD

Signature:

Darrel Lockard

Date:

7-3-25

Phone:

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>