

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.4			Y
2	7.5			Y
3	7.6			Y
4	7.6			Y
5	7.5			Y
6	7.6			Y
7	7.6	51.0	1.32	Y
8	7.6			Y
9	7.6			Y
10	7.6			Y
11	7.6			Y
12	7.5			Y
13	7.5			Y
14	7.5	52.7	1.43	Y
15	7.5			Y
16	7.6			Y
17	7.5			Y
18	7.5			Y
19	7.6			Y
20	7.6			Y
21	7.5	52.7	1.21	Y
22	7.5			Y
23	7.6			Y
24	7.5			Y
25	7.6			Y
26	7.6			Y
27	7.6			Y
28	7.5	54.0	1.38	Y
29	7.5			Y
30	7.5			Y
31	7.6			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have

minimums
been met for
this day?

County: Clatsop

Agency: CLATSOP COUNTY

ENTRY POINT

EP-A

PWS ID 4190416

Georgia-Pacific CLCP Wauna

Sample Period: July / 2025

Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH

7.2

PO4

0.5

(Orthophosphate)

Print Name:

Darrel Lockard Cert# 2853

Signature:

Darrel Lockard

Date:

8/8/25

Phone:

541-505-9968

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>