



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.6			Y
2	7.6			Y
3	7.5			Y
4	7.5			Y
5	7.5			Y
6	7.6	56.8	1.41	Y
7	7.6			Y
8	7.5			Y
9	7.5			Y
10	7.5			Y
11	7.5			Y
12	7.5			Y
13	7.5	59.7	1.46	Y
14	7.6			Y
15	7.6			Y
16	7.6			Y
17	7.5			Y
18	7.6			Y
19	7.6			Y
20	7.6	60.3	1.49	Y
21	7.6			Y
22	7.6			Y
23	7.6			Y
24	7.6			Y
25	7.6			Y
26	7.6			Y
27	7.6	59.5	1.54	Y
28	7.5			Y
29	7.5			Y
30	7.5			Y
31	7.5			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this day? County: Clatsop Agency: CLATSOP COUNTY

**ENTRY POINT
EP-A**

PWS ID 4190416

Georgia-Pacific CLCP Wauna

Sample Period: October / 2025
Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

PO4 0.5 (Orthophosphate)

Print Name: Darrel Lockard Cert# 2853

Signature: Darrel Lockard
Digitally signed by Darrel Lockard
DN: cn=Darrel Lockard, o=Delta Operations, ou,
email=brmcms@aol.com, c=US
Date: 2025.11.06 11:07:29 -0800

Date: 11/6/2025

Phone: 541-505-9968

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>