

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.43			Y
2	7.56			Y
3	7.51			Y
4	7.51			Y
5	7.51			Y
6	7.51	55.3	1.59	Y
7	7.51			Y
8	7.49			Y
9	7.48			Y
10	7.48			Y
11	7.55			Y
12	7.45			Y
13	7.51			Y
14	7.44			Y
15	7.49			Y
16	7.44			Y
17	7.49	54.0	1.55	Y
18	7.49			Y
19	7.56			Y
20	7.56			Y
21	7.55	58.5	1.53	Y
22	7.51			Y
23	7.58			Y
24	7.58	63.5	1.61	Y
25	7.57			Y
26	7.61			Y
27	7.53			Y
28	7.54			Y
29	7.54			Y
30	7.48			Y
31				
(No = N = Excursion)				
TOTAL N'S				

<<Have

minimums
been met for
this day?

County: Clatsop

Agency: CLATSOP COUNTY

ENTRY POINT

EP-A

PWS ID 4190416

Georgia-Pacific CLCP Wauna

Sample Period: November 2025

Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

PO4

(Orthophosphate)

7.2

0.5

Print Name:

Darrel Lockard Cert# 2853

Signature:

Darrel Lockard

Digitally signed by Darrel Lockard
DN: cn=Darrel Lockard, o=Delta Operations, ou,
email=bmcm5@aol.com, c=US
Date: 2025.12.03 16:03:04 -08'00'

Date:

12/3/2025

Phone:

541-505-9968

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>