

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.71			Y
2	7.73			Y
3	7.79		1.55	Y
4	7.70			Y
5	7.73	62.3	1.57	Y
6	7.72			Y
7	7.69			Y
8	7.66	62.1	1.58	Y
9	7.61			Y
10	7.55			Y
11	7.85			Y
12	7.85			Y
13	7.78			Y
14	7.88			Y
15	7.85	45.0	1.70	Y
16	7.82			Y
17	7.83			Y
18	7.96			Y
19	7.92			Y
20	8.05			Y
21	8.07			Y
22	8.14	43.2	2.08	Y
23	8.73			Y
24	8.54			Y
25	8.76			Y
26	8.57			Y
27	8.44			Y
28	8.29			Y
29	8.22			Y
30	8.21			Y
31	8.15			Y
(No = N = Excursion)				
TOTAL N'S				

<<Have

County: Clatsop

Agency: CLATSOP COUNTY

minimums
been met for
this day?

**ENTRY POINT
EP-A**

PWS ID 4190416

Georgia-Pacific CLCP Wauna

Sample Period: December 2025

Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH



PO4



(Orthophosphate)

7.55

1.55

Print Name:

Darrel Lockard Cert# 2853

Signature:

Darrel Lockard

Date:

1/5/26

Phone:

541-505-9968

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>