



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Y/N
1	7.42			Y
2	7.54			Y
3	7.56			Y
4	7.45			Y
5	7.43	56.2	1.84	Y
6	7.57			Y
7	7.59			Y
8	7.59			Y
9	7.59			Y
10	7.55			Y
11	7.57			Y
12	7.43	52.1	2.00	Y
13	7.44			Y
14	7.59			Y
15	7.60			Y
16	7.60			Y
17	7.70			Y
18	7.70			Y
19	7.70			Y
20	7.74			Y
21	7.70			Y
22	7.69			Y
23	7.68	62.6	1.71	Y
24	7.67			Y
25	7.70			Y
26	7.66	57.5	1.50	Y
27	7.72			Y
28	7.48			Y
29	7.49			Y
30	7.76			Y
31	7.77			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have County: Clatsop Agency: CLATSOP COUNTY

minimums  
been met for  
this day?

**ENTRY POINT  
EP-A**

**PWS ID 4190416**

**Georgia-Pacific CLCP Wauna**

**Sample Period: January 2026**

*Month/Year*

**Number of excursions\* during this month: 0** (Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months: 0** (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

*For OHA use only*

**Minimum Water Quality  
Parameters as set by**

pH 

7.2
-----

  
PO4 

0.50
------

(Orthophosphate)

Print Name: **Darrel Lockard Cert# 2853**

Signature: *Darrel Lockard*

Date: 2/9/26

Phone: 541-505-9968

**Send to DWP within 10 days after end of sampling period**

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>