



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.67			Y
2	7.67	56.2	1.79	Y
3	7.62			Y
4	7.61			Y
5	7.68			Y
6	7.68			Y
7	7.66			Y
8	7.64			Y
9	7.66	64.3	1.76	Y
10	7.62			Y
11	7.54			Y
12	7.70			Y
13	7.68			Y
14	7.63			Y
15	7.53			Y
16	7.64	61.9	1.84	Y
17	7.66			Y
18	7.66			Y
19	7.63			Y
20	7.60			Y
21	7.45			Y
22	7.72			Y
23	7.77	63.8	1.52	Y
24	7.77			Y
25	7.78			Y
26	7.75			Y
27	7.60			Y
28	7.68			Y
29				
30				
31				
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this day?

County: Clatsop Agency: CLATSOP COUNTY

ENTRY POINT
EP-A

PWS ID 4190416

Georgia-Pacific CLCP Wauna

Sample Period: February 2026
Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH **7.2**

PO4 **0.50** (Orthophosphate)

Print Name: **Darrel Lockard Cert# 2853**

Signature: **Darrel Lockard**
Digitally signed by Darrel Lockard
DN: cn=Darrel Lockard, o=Delta Operations, ou,
email=dlm@cm5@aol.com, c=US
Date: 2026.03.05 15:21:50 -08'00'

Date: **3/5/2026**

Phone: **541-505-9968**

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>