



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.63			Y
2	7.67			Y
3	7.69			Y
4	7.69			Y
5	7.77			Y
6	7.77			Y
7	7.77			Y
8	7.77			Y
9	7.74	65.3	1.90	Y
10	7.68			Y
11	7.74			Y
12	7.70			Y
13	7.79			Y
14	7.79			Y
15	7.73			Y
16	7.69	49.1	1.85	Y
17	7.83			Y
18	7.65			Y
19	7.65			Y
20	7.59			Y
21	7.69			Y
22	7.71			Y
23	7.72	62.4	1.44	Y
24	7.74			Y
25	7.78			Y
26	7.79			Y
27	7.69			Y
28	7.68			Y
29	7.72			Y
30	7.68	64.1	1.66*	Y
31	7.66			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have County: Clatsop Agency: CLATSOP COUNTY

minimums
been met for
this day?

**ENTRY POINT
EP-A**

PWS ID 4190416

Georgia-Pacific CLCP Wauna

Sample Period: March 2026

Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH **7.2**
PO4 **0.50** (Orthophosphate)

Print Name: Darrel Lockard Cert# 2853

Signature: Darrel Lockard Digitally signed by Darrel Lockard
DN: cn=Darrel Lockard, o=Delta Operations, ou,
email=dlmcm5@aol.com, c=US
Date: 2026.04.09 14:38:02 -0700

Date: 4/9/2026

Phone: 541-505-9968

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>

*Please see details included in cover letter and provided lab report.