

**Lead & Copper Rule Corrosion Control**

Sample Location	pH	Alk	Phos	Y/N
Unitizing lunchroom sink (1/10/23)	7.49	52.9	1.13	Y
Clockroom lunchroom sink (1/10/23)	7.33	50.0	1.35	Y
First User (1/10/23)	7.49	52.9	1.14	Y
Unitizing lunchroom sink (2/7/23)	7.59	62.2	1.33	Y
Clockroom lunchroom sink (2/7/23)	7.50	65.7	1.11	Y
First User (2/7/23)	7.54	68.2	1.28	Y
(No = N = Excursion)	0			
TOTAL N'S	0			

County: Clatsop Agency: CLATSOP COUNTY

<<Have minimums been met for this

**ENTRY POINT**  
**EP-A**  
**PWS ID 4190416**  
**Georgia-Pacific CLCP Wauna**  
**Sample Period: Jan-Feb / 2023 (lead and copper supplemental)**

Number of excursions\* during this month: 0  
*(Count the number of days when any WQP was less than the minimum required)*

Total excursions during the previous 5 months: 0  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)*

For OHA use only


**Minimum Water Quality Parameters as set by**

pH

PO4 (Orthophosphate)

7.2
0.5

Print Name: Travis Babikoff

Signature: 

Date: 3/1/23

Phone: 503-455-3248

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>