

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				
2	7.2				
3	7.3				
4	7.2				
5	7.4				
6	7.7				
7	7.4				
8	8.5				
9	8.0				
10	7.2				
11	7.2				
12	7.2				
13	7.2	1.81			
14	7.2				
15	8.4				
16	7.6				
17	8.4				
18	7.6				
19	7.2				
20	7.2				
21	7.2				
22	7.4				
23	8.5				
24	7.2				
25	7.2				
26	7.2				
27	7.2	1.78			
28	7.3				
29	7.6				
30	7.2				
31	8.5				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 90531

System Name: Jewell SD #8

Entry Point: Jewell school

Sample Period: Jan 2021
Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk 65 (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Ron Warner

Signature: Ron Warner

Date: 2-2-2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's