

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.7				
2	7.7				
3	7.6				
4	7.7				
5	8.1				
6	8.4				
7	8.0				
8	7.3				
9	7.3				
10	7.2				
11	7.3	172			
12	7.4				
13	7.2				
14	8.8				
15	8.5				
16	7.5				
17	7.6				
18	7.2				
19	7.4				
20	7.7				
21	7.7				
22	8.4				
23	7.9				
24	7.4				
25	7.5	178			
26	7.2				
27	7.6				
28	7.6				
29	7.6				
30	7.4				
31	7.5				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 90531

System Name: Jewelle SD. 8

Entry Point: School

Sample Period: August 2021
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk 60 (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Ron Wanner

Signature: R. Wanner

Date: 9/3/2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's