

Day	pH	Alk	Phos	Other	Y/N
1	7.2				
2	7.7				
3	7.2				
4	7.2				
5	7.2				
6	7.3				
7	7.2				
8	7.4				
9	7.5				
10	7.4	79			
11	7.6				
12	7.6				
13	7.4				
14	7.6				
15	7.5				
16	7.4				
17	7.4				
18	7.6				
19	7.4				
20	7.3				
21	7.6				
22	7.7				
23	7.7				
24	7.7	81			
25	7.8				
26	8.1				
27	7.8				
28	7.7				
29	7.3				
30	7.3				
31					

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 90531

System Name: Jewelle SD 8

Entry Point: School

Sample Period: 11/2021  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk 60 (Alkalinity)

PO4  (Orthophosphate)

Other  (\_\_\_\_\_)

Print Name: RON Wanner

Signature: R. Wanner

Date: 12/1/2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's