

Day	pH	Alk	Phos	Other	Y/N
1	7.7				
2	7.8				
3	7.6				
4	7.4				
5	7.3				
6	7.2				
7	7.2				
8	8.0				
9	7.3	71			
10	7.5				
11	7.4				
12	7.3				
13	7.4				
14	7.4				
15	7.5				
16	7.9				
17	7.6				
18	7.5				
19	7.2				
20	7.2				
21	7.6				
22	7.4				
23	7.4	80			
24	7.4				
25	7.4				
26	7.4				
27	7.4				
28	7.4				
29	7.2				
30	7.5				
31					

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 90531

System Name: Jewelle SD 8

Entry Point: School

Sample Period: 4/2022
Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk 60 (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: RON Wanner

Signature: R. Wanner

Date: _____

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's