

Day	pH	Alk	Phos	Other	Y/N
1	7.6				
2	7.2				
3	7.6				
4	7.5				
5	7.2				
6	7.6				
7	7.9				
8	7.7				
9	7.4				
10	7.4	80			
11	7.4				
12	8.2				
13	8.0				
14	7.8				
15	7.6				
16	7.4				
17	7.3				
18	7.4				
19	7.4				
20	8.5				
21	7.7				
22	7.6				
23	7.5				
24	7.4	76			
25	7.3				
26	7.3				
27	7.2				
28	8.3				
29	7.3				
30	7.5				
31	7.4				

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41

System Name: Jewelle SD. 8

Entry Point: School

Sample Period: 8/2022  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

Minimum Water Quality Parameters as set by

pH

Alk  (Alkalinity)

PO4  (Orthophosphate)

Other  (\_\_\_\_\_)

Print Name: RON Wannex

Signature: R. Wannex

Date: 9/4/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's