

Day	pH	Alk	Phos	Other	Y/N
1	7.8				
2	7.9				
3	7.5				
4	7.8				
5	7.8				
6	7.3				
7	7.4				
8	7.4				
9	7.6				
10	7.7	84			
11	8.2				
12	7.9				
13	7.7				
14	7.4				
15	7.2				
16	7.2				
17	7.3				
18	8.5				
19	8.3				
20	7.6				
21	7.3				
22	7.3				
23	7.6				
24	7.8	86			
25	8.3				
26	8.1				
27	7.8				
28	7.8				
29	7.8				
30	7.8				
31					

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 90531

System Name: Jewelle SD. 8

Entry Point: School

Sample Period: 9-2022
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk 60 (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: RON Wanner

Signature: *Ron Wanner*

Date: 10-2-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's