

Day	pH	Alk	Phos	Other	Y/N
1	7.9				
2	7.8				
3	7.8				
4	7.9				
5	7.9				
6	7.9				
7	8				
8	8	.72			
9	8				
10	8				
11	8				
12	8				
13	8.1				
14	8				
15	8				
16	7.9				
17	8				
18	7.9				
19	8				
20	7.9				
21	8				
22	8	.80			
23	8				
24	8				
25	8				
26	7.9				
27	8				
28	8.1				
29	8.1				
30	8				
31	8				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 90531

System Name: Jewelle SD 8

Entry Point: School

Sample Period: 10/2022
Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk 60 (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: RON Wanner

Signature: R. Wanner

Date: 11/1/2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's