

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	8.1				
2	8.1				
3	8.1				
4	8.2				
5	8.1				
6	8.1				
7	8.2				
8	8.1				
9	8.1				
10	8.1				
11	8.1	8.2			
12	8.1				
13	8.1				
14	8.1				
15	8.1				
16	8.1				
17	8.1				
18	8.1				
19	8.1				
20	8.1				
21	8.1				
22	8.0	7.9			
23	8.1				
24	8.1				
25	8.1				
26	8.1				
27	8.1				
28	8.1				
29	8.1				
30	8.1				
31	8.0				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 90531

System Name: Jewelle SD. 8

Entry Point: School

Sample Period: 1/2023
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk 60 (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: Ron Wanner

Signature: Ron Wanner

Date: 2/3/2023

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0