

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pН	Alk	Phos	Other	Y/N	<-Have ENTRY POINT
1	8.4					minimums ENIKIPUINI
2	7,8					this day? PWS ID: 41 90531
3	7,7					System Name: Jewell SD ⁷¹ 8
4	7,5					
5	7.4					Entry Point:
6	7.3	egyzekkenijszticeli kizikitatul				Sample Period: ///23
7	8.2	nerupolostanisti keteretti taino				Month/Year
8	8,3					Number of excursions* during this month:
9	7,6	acerikantu capta ya Pacilona ka				(Count the number of days when any WQP was
10	7,5					less than the minimum required)
11	7.4	A				
12	7.3					Total excursions during the previous 5 months:
13	712					(Over 9 excursions in 6 months is a violation. Entry
14	7.3					Point and Distribution excursions are cumulative)
15	7.8	.83				For OHA use only
16	7.5					I OF OTTA use only
17	7.4					Minimum Water Quality
18	7,9					Parameters as set by
19	7.7					Kommanatarihanihanihanihanihanih
20	7.6					pH 7,2
21	7.4					Alk CO (Alkalinity)
22	7.5					PO4 (Orthophosphate)
23	7,4					Other ()
24	7,3					
25	7,4					
26	7.6					
27	7.5				And a second	Print Name: Bonald Wanner
28	7,4					Signature: Frided Warre
29	7,4	.88				Date:
30	7,3		T			
31	-					Send to DWP within 10 days after end of sampling period
No =	Io = N = Excursion) Total N's					

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/