Oregon Health Authority

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7,4				
2	7,2				
3	7,2				
4	7,6				
5	7,4				
6	7,3				
7	8,0				
8	8,0				
9	7,9	.72			
10	7,9				
11	7,8				
12	7,9				
13	7,9				
14	7,4				
15	7,2				
16	7,2				
17	7,3				
18	7,5				
19	7,5				
20	7,5				
21	7,5				
22	7,8				
23	7,8	.81			
24	7,6				
25	7,5				
26	7,5				
27	7,5				
28	7,3				
29	7,5				
30	7,5				
31	7,3				

(No = N = Excursion) Total N's [ ]

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 | 9 | 0 | 5 | 3 | 1

System Name: Jewell SD #8

Entry Point: 12/2023

Sample Period: 12/2023
Month/Year

Number of excursions* during this month:____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months:____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

┌─ For OHA use only ─────────────

Minimum Water Quality Parameters as set by

pH | [7,2]
Alk | [60] (Alkalinity)
PO4 | [ ] (Orthophosphate)
Other | [ ] (_____)

Print Name: Ronald Wanner
Signature: Ronald Wanner
Date: 12/31/2023

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: http://healthoregon.org/dwp/