

## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

Day	рН	Alk	Phos	Other	Y/N	< <have entry="" point<="" th=""></have>
1	7,7					IIIIIIIIIIIII
2	7, 3					been met for this day? PWS ID: 41 9 6 3 1
3	7,4					System Name: Jewell SD8
4	7,2					
5	7.3					Entry Point:
6	7,3					Sample Period: May 2024
7	7,6					Month/Year
8	7,4	,78				Number of excursions* during this month:
9	7,5					(Count the number of days when any WQP was
10	7,3					less than the minimum required)
11	7, 2,	4				
12	7,3					Total excursions during the previous 5 months:
13	716					(Over 9 excursions in 6 months is a violation. Entry
14	7,7					Point and Distribution excursions are cumulative )
15	7,3					For OHA use only
16	7,2					
17	7,2					Minimum Water Quality
18	7.3					Parameters as set by
19	7,7					pH 7, Z
20	7,4					Alk 60 (Alkalinity)
21	7,3					PO4 (Orthophosphate)
22	7.5	182				
23	713					Other
24	7,4					· ·
25	7,6					
26	7,9					
27	7.7	PRINCIPAL SPECIAL SPEC				Print Name: Low Wanner
28	7.4					Signature: Solvani
29	7.4	1.86				Date: 6/2/2024
30	7,4					
31	7.4					Send to DWP within 10 days after end of sampling period
No =	N = Ex	cursio	n) Tot	al N's	Ò	

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/