

Day	pH	Alk	Phos	Other	Y/N
1	7.4				
2	7.6				
3	7.8				
4	7.4				
5	8.4	.58			
6	7.6				
7	7.4				
8	7.2				
9	7.2				
10	7.2				
11	7.2				
12	7.2	.91			
13	7.3				
14	7.5				
15	7.9				
16	8.0				
17	7.6				
18	7.5				
19	7.4				
20	7.3				
21	7.2				
22	7.2				
23	7.2				
24	7.2				
25	7.2				
26	7.2	.40			
27	7.6				
28	7.5				
29	7.2				
30	7.5				
31	—				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 90531

System Name: Jewell SD 8

Entry Point: _____

Sample Period: June 2024
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk = (Alkalinity)

PO4 (Orthophosphate)

Other ()

Print Name: Don Wanner

Signature: *Don Wanner*

Date: 6/30/2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0