

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.5				
2	7.2				
3	7.3				
4	7.3				
5	7.2				
6	7.7				
7	8.2				
8	7.7				
9	7.6				
10	7.4	.79			
11	7.3				
12	7.2				
13	7.2				
14	8.2				
15	8.0				
16	7.7				
17	7.3				
18	7.2				
19	7.3	.89			
20	7.4				
21	7.5				
22	8.2				
23	8.0				
24	7.2				
25	7.5				
26	7.4				
27	7.2	.92			
28	7.5				
29	7.8				
30	8.1				
31	7.4				

<<Have minimums been met for this day?

**ENTRY POINT**

PWS ID: 41 90531

System Name: Jewelle SD. 8

Entry Point: School

Sample Period: \_\_\_\_\_  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 7.2

Alk 60 (Alkalinity)

PO4   (Orthophosphate)

Other   ( )

Print Name: Don Wanner

Signature: [Signature]

Date: 1/1/2025

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0