

Day	pH	Alk	Phos	Other	Y/N
1	7.5				
2	7.3				
3	7.8				
4	8.2				
5	7.8				
6	7.5				
7	7.2				
8	7.2	182			
9	7.3				
10	7.2				
11	7.3				
12	8.2				
13	7.3				
14	7.2				
15	7.4				
16	7.2	178			
17	7.8				
18	7.7				
19	7.4				
20	7.3				
21	7.2				
22	7.9				
23	7.6				
24	7.3				
25	7.5				
26	7.6				
27	7.4				
28	7.3				
29	7.3	189			
30	8.2				
31	6.0				

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day? **ENTRY POINT**

PWS ID: 41 90531

System Name: Jewelle SD. 8

Entry Point: School

Sample Period: Jan 2025
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

Alk 60 (Alkalinity)

PO4 (Orthophosphate)

Other (_____)

Print Name: RON Wanner

Signature: [Signature]

Date: 2/2/2025

Send to DWP within 10 days after end of sampling period