

## Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.6				
2	7.5				
3	7.3				
4	7.5				
5	7.4	1.99			
6	7.5				
7	7.6				
8	8.2				
9	8.2				
10	7.6				
11	7.3				
12	7.2				
13	7.2				
14	7.4				
15	7.4	1.87			
16	7.4				
17	7.4				
18	7.2				
19	7.7				
20	7.7				
21	7.3				
22	7.3				
23	7.4				
24	7.4				
25	7.5				
26	7.5				
27	7.7	1.88			
28	7.6				
29					
30					
31					

(No = N = Excursion) Total N's

<<Have minimums been met for this day?

### ENTRY POINT

PWS ID: 41 90531

System Name: Jewelle SD. 8

Entry Point: School

Sample Period: 2/25  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_  
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

#### Minimum Water Quality Parameters as set by

pH 7.2  
Alk 60 (Alkalinity)  
PO4  (Orthophosphate)  
Other  ( )

Print Name: RON Wanner

Signature: R. Wanner

Date: 3/2/2025

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>