

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5				
2	7.4				
3	7.2				
4	7.2				
5	7.2				
6	8.2				
7	7.5				
8	7.2				
9	7.2	78			
10	7.2				
11	8.2				
12	7.6				
13	7.4				
14	7.4				
15	7.2				
16	8.0				
17	7.5				
18	7.4	69			
19	7.3				
20	7.5				
21	7.6				
22	8.2				
23	7.5				
24	7.4				
25	7.3				
26	7.2				
27	7.4				
28	7.2	82			
29	8.2				
30	7.4				
31					

(No = N = Excursion) Total N's 0

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 90531

System Name: Jewelle SD 8

Entry Point: School

Sample Period: April 2025
Month/Year

Number of excursions* during this month: _____
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months: _____
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2
Alk 60 (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: Don Wanner

Signature: Don Wanner

Date: 5/2/2025

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>