

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				
2	7.3				
3	7.4				
4	8.2				
5	7.2				
6	7.2				
7	7.2	89			
8	7.3				
9	7.6				
10	8.2				
11	7.2				
12	7.2				
13	7.3				
14	7.7				
15	7.7				
16	7.6	71			
17	8.1				
18	8.1				
19	7.6				
20	7.2				
21	7.4				
22	7.4				
23	7.4				
24	7.6				
25	7.8				
26	7.8				
27	7.6	79			
28	7.5				
29	7.4				
30	7.3				
31	7.4				

(No = N = Excursion) Total N's X

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 90531

System Name: Jewelle SD 8

Entry Point: School

Sample Period: 5/2025

Month/Year

Number of excursions* during this month: _____

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality
Parameters as set by**

pH 7.2
Alk 60 (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: RON Wanner

Signature: R. Wanner

Date: 6/1/25

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>