

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3				
2	7.4				
3	7.2				
4	7.5				
5	7.5				
6	7.2				
7	7.4				
8	7.3				
9	7.2	133			
10	7.8				
11	7.7				
12	7.9				
13	7.7				
14	7.8				
15	7.9				
16	7.4				
17	7.4				
18	7.4				
19	7.7	78			
20	7.5				
21	7.7				
22	7.8				
23	7.5				
24	7.4				
25	7.4				
26	7.5				
27	7.3				
28	7.2	76			
29	8.1				
30	8.0				
31					

(No = N = Excursion) Total N's

<<Have
minimums
been met for
this day?

ENTRY POINT

PWS ID: 41 90531

System Name: Jewelle SD 8

Entry Point: School

Sample Period: 6/2025
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was
less than the minimum required)

Total excursions during the previous 5 months:
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
Alk 60 (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: RON Wanner

Signature: R. Wanner

Date: 7/6/2025

Send to DWP within 10 days after end of
sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>