

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.6				
2	7.5				
3	7.6				
4	7.5				
5	7.6				
6	7.6	.87			
7	7.7				
8	7.5				
9	7.4				
10	7.4				
11	7.2				
12	7.7				
13	7.6				
14	7.4	.78			
15	8.0				
16	8.1				
17	7.7				
18	7.5				
19	7.4				
20	7.5				
21	7.5				
22	7.4				
23	7.4				
24	7.6				
25	8.0				
26	7.5	.91			
27	7.3				
28	7.8				
29	7.8				
30	7.6				
31	7.6				

<<Have

minimums  
been met for  
this day?

**ENTRY POINT**

PWS ID: 41

System Name: Jewell SD #8

Entry Point: \_\_\_\_\_

Sample Period: 8/2025  
Month/Year

Number of excursions\* during this month: \_\_\_\_\_

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

**Minimum Water Quality  
Parameters as set by**

pH   
Alk   
PO4   
Other

(Alkalinity)

(Orthophosphate)

( )

Print Name: Don Wanner

Signature: Don Wanner

Date: 8/31/2025

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>