

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.2				
2	7.2				
3	7.4	.77			
4	7.2				
5	7.2				
6	7.2				
7	7.2				
8	7.2				
9	7.8				
10	7.9				
11	7.7				
12	7.6	.88			
13	7.4				
14	7.2				
15	7.2				
16	7.3				
17	7.2				
18	7.7				
19	7.6				
20	7.5				
21	7.3				
22	7.2				
23	7.2				
24	7.2				
25	7.3				
26	7.2				
27	7.2	.91			
28	7.2				
29	7.3				
30	7.2				
31					

(No = N = Excursion) Total N's 0

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41 90531

System Name: Jewell SD #8

Entry Point: Jewell School

Sample Period: NOV 2025
Month/Year

Number of excursions* during this month: _____

(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)



For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
Alk (Alkalinity)
PO4 (Orthophosphate)
Other ()

Print Name: RON WANNER

Signature: Ron Wanner

Date: 12/1/2025

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350

Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>