

Day	pH	Alk	Phos	Other	Y/N
1	7.3				
2	7.2				
3	7.5				
4	7.5				
5	7.4	.89			
6	7.4				
7	7.4				
8	7.4				
9	7.7				
10	7.7				
11	7.6				
12	7.6				
13	7.5				
14	7.5				
15	7.6				
16	7.6	.69			
17	7.5				
18	7.4				
19	7.4				
20	7.4				
21	7.7				
22	7.7				
23	7.6				
24	7.6				
25	7.6				
26	7.6				
27	8.0				
28	7.9	.72			
29	7.7				
30	7.6				
31	7.4				

<<Have minimums been met for this day?

ENTRY POINT

PWS ID: 41

System Name: Jewell SD. #8

Entry Point: Jewell school

Sample Period: 1/2026
Month/Year

Number of excursions* during this month: _____
 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: _____
 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH

Alk (Alkalinity)

PO4 (Orthophosphate)

Other

Print Name: RON WANNER

Signature: Ron Wanner

Date: 2/1/26

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's