

## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

Day	рН	Alk	Phos	Other	Y/N	< <have< th=""></have<>
1	8,5					minimums ENTRY POINT
2	8,1					been met for this day? PWS ID: 41 9 0 5 3 1
3	8,0					
4	7,8					System Name: Tewelle SD. 8
5	7,4					Entry Point: School
6	8,3					Sample Period: $\frac{9}{202}$
7	7,8					Month/Year
8	7.4					Number of excursions* during this month:
9	8,0					(Count the number of days when any WOP was
10	7,2					less than the minimum required)
11	7,3	**				
12	7,8					Total excursions during the previous 5 months:
13	7.4				·	(Over 9 excursions in 6 months is a violation. Entry
14	7.4	82				Point and Distribution excursions are cumulative)
15	8,0					For OHA use only
16	7,4					I OF OTTA USE OTTY
17	8,2					Minimum Water Quality
18	7,4					Parameters as set by
19	7,6					
20	7,4					pH 7, 2
21	713					Alk 60 (Alkalinity)
22	7.5					PO4 (Orthophosphate)
23	815					Other
24	7,4					
25	8,4					
-	7.4					^
27	7,4					Print Name: Son Wanner Signature: To Warne
28	7,4	78				Signature: To Warn!
29	7,4				_	Date: 5/1/21
30	7,3					Send to DWP within 10 days after end of
31						sampling period
o = N = Excursion) Total N's						

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/