

## Water Quality Parameter Monitoring Form

## **Lead & Copper Rule Corrosion Control**

Day	рН	Alk	Phos	Other	Y/N	< <have< th=""></have<>
1	80					minimums ENTRY POINT
2	8,0					been met for this day? PWS ID: 41 9 0 5 3 1
.3	8,0					Line day.
4	8,1					System Name: Tewelle SD. 8
5	8,0					Entry Point: School
6	8,0					Sample Period: Nov ZOZZ
7	8,0					Month/Year
8	8,1					Number of excursions* during this month:
9	8,1	80				(Count the number of days when any WQP was
10	8,1					less than the minimum required)
11	8.0	í	7			
12	8,0					Total excursions during the previous 5 months:
13	8,0		-			(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)
14	8,0			and the same of th		i onit and Distribution excursions are cumulative )
15	8,0		-			For OHA use only
16	8.1					
17	8,1					Minimum Water Quality
18	8,0					Parameters as set by
19	8,0				and the same of th	pH 7.2
20	8,0					Alk 60 (Alkalinity)
22	8,0					PO4 (Orthophosphate)
23	8,0	015				Other ()
24	8.1	82				
25	8.0				$\vdash$	· ·
26	8.1					
27	8,1		1			Print Name: Son Wanner
28	8,0				$\vdash \vdash \vdash$	
29	8,0					Signature: For Warne
30	8,0				-	Date: 11/30/2022
31	0,				damand da	Send to DWP within 10 days after end of
(No = 1	V = Exc	cursior	) Tota	al N's		sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/